PARKHOUSE ENTERPRISES LTD.

INDEPENDENT CONSULTANTS & SPECIALIST MATERIAL SUPPLIERS

3 Dunstan Hill, Kirton in Lindsey, Gainsborough, North Lincolnshire DN21 4DU Telephone (01652) 648270: E-mail ParkhouseEnt@aol.com

CEMENT TEST RESULTS

Client :- Dragon Cement 52.5 R

Our Reference :- DG52-7

Sample :- CEM 1 52.5 R

Sand :- German
Date of receipt of sample :- 18-Feb-14

Date of tests :- 18-Feb-14 to 18-Mar-14

RESULTS

INITIAL SETTING TIME 135 mins (BS EN196 PART 3:2005)

COMPRESSIVE STRENGTH :- MORTAR PRISMS (BS EN196 PART 1:2005)

AT 2 DAYS 36.1 MPa (Mean of 6 results, none discarded)

AT 28 DAYS 61.5 MPa (Mean of 6 results, none discarded)

CHEMICAL COMPOSITION: - by mass

Loss on ignition 1.55 % (BS EN196 PART2:2013)

Insoluble Residue 0.47 % (BS EN196 PART2:2013)

S. Sykes Senior Technician