PARKHOUSE ENTERPRISES LTD.

INDEPENDENT CONSULTANTS & SPECIALIST MATERIAL SUPPLIERS

3 Dunstan Hill, Kirton in Lindsey, Gainsborough, North Lincolnshire DN21 4DU Telephone (01652) 648270: E-mail ParkhouseEnt@aol.com

CEMENT TEST RESULTS

Client :- Dragon Cement 52.5 R

Our Reference :- DG52- 30

Sample :- CEM 1 52.5 R

Sand :- German
Date of receipt of sample :- 11-Aug-14

Date of tests :- 11-Aug-14 to 8-Sep-14

RESULTS

INITIAL SETTING TIME 180 mins (BS EN196 PART 3:2005)

COMPRESSIVE STRENGTH :- MORTAR PRISMS

37.7 MPa

(BS EN196 PART 1:2005)

(Mean of 6 results, none discarded)

AT 28 DAYS 62.7 MPa (Mean of 6 results, none discarded)

CHEMICAL COMPOSITION: by mass

AT 2 DAYS

Loss on ignition 2.15 % (BS EN196 PART2:2013)

Insoluble Residue 0.48 % (BS EN196 PART2:2013)

Sulphate 3.29 % (BS EN196 PART2:2013)

S. Sykes Senior Technician