



CEMENTOS ALFA, S.A,

Plant: MATAPORQUERA

ER Certificate: ER-0572/1998



QUALITY ANALYSIS CERTIFICATE - CEMENT

TYPICAL RESULTS

Cement Type: CEM I 52,5 R ma (EN 197-1)

PERIOD: APRIL 2014

CE: 0099/CPR/A33/0831

The Quality Management System adopted in our company for the production and commercialization of cements and clinker, complies with UNE-EN-ISO 9001:2008, and it is certified by AENOR. It is also certified under IQNet network.

TESTS	Results	Specification EN 197-1
<b>Chemical Characteristics</b>		
Loss on Ignition %	1,46	≤ 5,0
SiO <sub>2</sub> %	20,93	
Al <sub>2</sub> O <sub>3</sub> %	3,88	
Fe <sub>2</sub> O <sub>3</sub> %	3,12	
CaO %	64,26	
MgO %	1,38	
Na <sub>2</sub> O %	0,13	
K <sub>2</sub> O %	0,72	
Insoluble Residue %	0,45	≤ 5,0
Sulphates (SO <sub>3</sub> ) %	3,31	≤ 4,0
Chlorides %	0,00	≤ 0,10
<b>Physical and Mechanical Characteristics</b>		
Normal Consistency Water %	30,5	
Initial Setting Time min	150	≥ 45
Final Setting Time min	200	
Soundness (Le Chatelier) mm	0,5	≤ 10
Specific Surface (Blaine) cm <sup>2</sup> /g	4950	
Compressive Strength at 2 days MPa	41,3	≥ 30,0
Compressive Strength at 28 days MPa	69,0	≥ 52,5
<b>Other Characteristics</b>		
Na <sub>2</sub> O equiv. %	0,60	≤ 0,75
<b>Bogue Composition (mineral phases)</b>		
C <sub>3</sub> S %	60,1	
C <sub>2</sub> S %	21,3	
C <sub>3</sub> A %	5,0	
C <sub>4</sub> AF %	8,6	

R-25-4-52/5-Z

Quality Manager

Barrio la Estación, s/n.  
39410 Mataporquera (Cantabria)  
Tel. 942 770 058  
Fax 942 770 243  
info@alfainforma.com



GRUPO  
CEMENTOS  
PORTLAND  
VALDERRIVAS